

Server Rack 21U

Item	Minimum Requirement	Compliance	
		Yes/No	If “No” Bidder’s response
Brand	(Specify)		
Type	21U		
	19"equipment mounting Cabinet, Minimum Depth of 800mm.		
Make	(Specify)		
Model No	(Specify)		
Country of Manufacture	(Specify)		
Doors (Front/Back)	Should have Lockable Perforated Front/Rear Doors		
Side Panels	Should be removable and lockable		
Cable Exits	Should have Top and Bottom cable exits.		
Rack Cooling	Should have redundant cooling/ exhaust system		
Power	Should include with proper power distribution bar to power up the equipments		
Warranty	3 years comprehensive on-site supplier authorized warranty (Labour & parts). Maximum response time of 1 business days and 2 business day resolution		